ITEM NO.	PART NUMBER	DESCRIPTION	QTY.	MATERIAL	ULTIMATE STRENGTH
1	ASH-66-BC	ANCHOR SHACKLE	2	FORGED STEEL	60,000 LBS.
2	LOO-50-15	OVAL EYE/OVAL EYE	2	FORGED STEEL	50,000 LBS.
3	SYCR-56	90° SOCKET Y-CLEVIS	2	DUCTILE IRON	30,000 LBS.
4	Y2V\$050\$1845	TRIANGULAR TANGENT YOKE	1	STEEL	50,000 LBS.
5	-	LS SUSPENSION CLAMP	-	ALUMINUM	25,000 LBS.
6	_	Y-CLEVIS INSULATOR	_	COMPOSITE	

PA	APER SIZE	DRAWING NUMBER					
	В	X2VS2YB30B2					
RE	EV DATE	DESCRIPTION	REV	ВҮ			

3.50 15.00 9.00 <del>-----</del> 18.00 ---

NOTE: INSULATORS AND **CONDUCTOR KIT SOLD SEPARATELY** 

ASSEMBLY CAT. NO. X2VS2YB30B2

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN: **INCHES** TOLERANCES ARE: X +/- 0.1 .XX +/- 0.03 +/- 0.015 .XXX ANGLES +/- 1.0

WWW.MACLEANPOWER.COM

DO NOT SCALE DRAWING SHEET1 DRAWING DESCRIPTION:

V-STRING

**ASSEMBLY** 

CAD GENERATED DRAWING DO NOT MANUALLY UPDATE DESIGN DATE: 3/25/24 JIP DRAWN BY:

ENGINEER: APPROVED:

DRAWING SCALE: 1:1

This drawing contains confidential information that is the property of MacLean Power, L.L.C. ("MacLean"). Use of MacLean's confidential information without MacLean's express written consent is strictly prohibited and may expose you to legal liability. If you believe that you received this material in error, please destroy it or return it to "MacLean Power, L.L.C., 11411 Addison Street, Franklin Park, Illinois 60131, USA."