
ITEM NO. PART NUMBER **DESCRIPTION** QTY. MATERIAL **ULTIMATE STRENGTH** 2 60,000 LBS. ASH-66-BC **ANCHOR SHACKLE FORGED STEEL** SYCR-87 2 50,000 LBS. 90° SOCKET Y-CLEVIS **DUCTILE IRON** 50,000 LBS. 3 Y2VS050S1845 TRIANGULAR TANGENT YOKE **STEEL** 4 LS SUSPENSION CLAMP **ALUMINUM** 25,000 LBS.

Y-CLEVIS INSULATOR

| PAPER | R SIZE | DRAWING NUMBER | | |
|-------|--------|----------------|-----|----|
| | В | X2VS2YB50A2 | | |
| REV | DATE | DESCRIPTION | REV | ВҮ |
| | | | | |
| | | | | |
| | | | | |



NOTE: INSULATORS AND CONDUCTOR KIT SOLD SEPARATELY

ASSEMBLY CAT. NO. X2VS2YB50A2

This drawing contains confidential information that is the property of MacLean Power, L.L.C. ("MacLean"). Use of MacLean's confidential information without MacLean's express written consent is strictly prohibited and may expose you to legal liability. If you believe that you received this material in error, please destroy it or return it to "MacLean Power, L.L.C., 11411 Addison Street, Franklin Park, Illinois 60131, USA."

5

| DIMENSIONS AF | VISE SPECIFIED RE IN: |
|---------------|--------------------------|
| INC | HES |
| TOLERAN | ICES ARE: |
| .X | +/- 0.1 |
| .XX | +/- 0.03 |
| .XXX | +/- 0.015 |
| ANGLES | +/- 1.0 |

COMPOSITE



> V-STRING ASSEMBLY

| CAD GENERATED DRAWING DO NOT MANUALLY UPDATE | | | | | |
|---|-----|--|--|--|--|
| DESIGN DATE: 3/25/24 | | | | | |
| DRAWN BY: | JIP | | | | |
| ENGINEER: | | | | | |
| APPROVED: | | | | | |

DRAWING SCALE: 1:1

8

7

6

4

3

2