
ULTIMATE STRENGTH ITEM NO. CAT. NUMBER **DESCRIPTION** QTY. **MATERIAL** ASH-66-BC **ANCHOR SHACKLE** 2 FORGED STEEL 60,000 LBS. 60,000 LBS. 2 CL-6 **CHAIN LINK** 1 FORGED STEEL 3 Y2DT060D1800 YOKE PLATE **DUCTILE IRON** 60,000 LBS. 1 ASH-56-BC **ANCHOR SHACKLE** 2 FORGED STEEL 40,000 LBS. 4 SYCR-56 30,000 LBS. 5 90° SOCKET Y-CLEVIS 2 **DUCTILE IRON** YOKE PLATE 60,000 LBS. Y2DR060D1800 **DUCTILE IRON** 6 QUADRANT STRAIN CLAMP 35,000 LBS. **ALUMINUM** 

Y-CLEVIS INSULATOR

PAPE	R SIZE	DRAWING NUMBER	
	В	X3DE2YB30A2	
REV	DATE	DESCRIPTION	REV BY



NOTE: INSULATORS AND **CONDUCTOR KIT SOLD SEPARATELY** 

ASSEMBLY CAT. NO. X3DE2YB30A2

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN: **INCHES** TOLERANCES ARE: +/- 0.1 +/- 0.03 .XXX +/- 0.015 ANGLES +/- 1.0

WWW.MACLEANPOWER.COM

DRAWING NUMBER: X3DE2YB30A2 SHEET NAME
SHEET1 ] OF ]

DO NOT SCALE DRAWING CAD GENERATED DRAWING DO NOT MANUALLY UPDATE

DESIGN DATE: 3/22/24

JIP DRAWN BY: **DEAD END** ENGINEER: **ASSEMBLY** APPROVED: DRAWING SCALE: 1:1

This drawing contains confidential information that is the property of MacLean Power, L.L.C. ("MacLean"). Use of MacLean's confidential information without MacLean's express written consent is strictly prohibited and may expose you to legal liability. If you believe that you received this material in error, please destroy it or return it to "MacLean Power, L.L.C., 11411 Addison Street, Franklin Park, Illinois 60131, USA."

COMPOSITE