
8	7	6	5	4	3

ITEM NO	D. PART NUMBER	DESCRIPTION	QTY.	MATERIAL	ULTIMATE STRENGTH
1	ASH-66-BC	ANCHOR SHACKLE	2	FORGED STEEL	60,000 LBS.
2	SYCR-87	SOCKET Y-CLEVIS	2	DUCTILE IRON	50,000 LBS.
3	ASM-6168-41	YOKE PLATE	1	STEEL	50,000 LBS.
4	-	CF SUSPENSION CLAMP	-	ALUMINUM	25,000 LBS.
5	-	Y-CLEVIS INSULATOR	-	COMPOSITE	-



6

ASSEMBLY CAT. NO. X3RV2YB50A2

-5

This drawing contains confidential information that is the property of MacLean Power, L.L.C. ("MacLean"). Use of MacLean's confidential information without MacLean's express written consent is strictly prohibited and may expose you to legal liability. If you believe that you received this material in error, please destroy it or return it to "MacLean Power, L.L.C., 11411 Addison Street, Franklin Park, Illinois 60131, USA."

8

D

С

B

A



3.5Ó

	2	1	
PAPER	SIZE	DRAWING NUMBER	
	В	X3RV2YB50A2	
REV	DATE	DESCRIPTION	REV BY

NOTE: INSULATORS AND CONDUCTOR KIT SOLD SEPARATELY

С

DRAWING NUMBER:	DO NOT SCA	LE DRAWING	1	
X3RV2YB50A2	CAD GENERATED DRAWING DO NOT MANUALLY UPDATE			
DRAWING DESCRIPTION:	DESIGN DATE: 3/25/24			
	DRAWN BY:	JIP		
V-STRING ASSEMBLY	ENGINEER:			
V SHRING / ROSEIVIDET	APPROVED:			
DRAWING SCALE:]:]				
2	1			